

19 January 1988

MEMORANDUM FOR: Chief, New Building Communications Program Division, OIT

FROM:

Chief, New Building Project Office, OL

SUBJECT: Auxiliary Conduit Modification

1. On January 12, Scott J. and GSA met with Contel representatives to review the proposed rerouting of the non-secure conduit. This rerouting was between column lines 7 to 17a and B and E on the ground floor of the NHB.

2. In order to maintain the requisite 10 inch clearance above the suspended ceiling, Contel proposed a routing along the wall on the ground floor separating office and UPS spaces.

3. The plan is acceptable as briefed with three caveats:

- a. work during the evening shift.
- b. maintain maximum clearance possible as discussed for access panels, pull boxes, and valves.
- c. provide shop drawings for inclusion in as-built documentation to be maintained by FMD.

4. We appreciate your cooperation in developing this plan. I am sure you can understand our sensitivity with regard to working in areas which still have considerable construction activity to take place.

OL/NBPO [redacted] 19Jan88
Orig - Adse
1 - OL/NBPO Subject
1 - OL/NBPO Chrono
1 - OL Reader

OL 2002-SS